

EXHIBIT A

PUBLIC WORKS WATER DISTRIBUTION DESIGN STANDARDS

Section 1
Water Distribution

Section 1 WATER DISTRIBUTION

1.1 PURPOSE

- A. The purpose of these Standards is to ensure the development of a water distribution system which will;
- 1) be of adequate design to meet all expected domestic, commercial and industrial demands including: fire flows within the design life;
 - 2) have sufficient structural strength to withstand all external loads which may be imposed;
 - 3) be of materials resistant to both corrosion and erosion;
 - 4) be economical and safe to build and maintain; and
 - 5) meet all design requirements of the Oregon Health Authority (“OHA”).
- B. Alternate materials and methods will be considered for approval on the basis of these objectives. These Standards cannot provide for all situations. They are intended to assist but not to substitute for competent work by professional design engineers.

1.2 APPLICABILITY

- A. These Standards shall govern all construction and upgrading of all public water distribution facilities in Burlington Water District (“District”) and applicable work within its Service Area.
- B. Permanent water distribution facilities shall be provided to all properties within the District in accordance with these Standards. In general, this shall be interpreted to mean that permanent water distribution facilities shall be provided for existing legal lots of record at the time development occurs, and for new legal lots of record created by a major or minor partitioning or subdivision of land at the time of partitioning or subdivision.

1.3 SPECIAL ITEMS

- A. The design of the following are considered special items and are not covered in detail in these Standards:
- 1) Water Distribution Pump Stations
 - 2) Reservoirs
 - 3) Wells
 - 4) Treatment Plants
 - 5) Pressure Regulating Devices

- 6) Flow Measurement Devices
- 7) Relining of the Existing Water Mains
- 8) Chemical Addition or pH Adjustment
- 9) Bridge Crossings
- 10) Creek or Stream Crossings

- B. Review and approval of the above special items by the District shall be required. When requested by the District, full design calculations shall be submitted for review prior to approval. Special items may also require review and approval by the OHA.

1.4 APPROVAL OF ALTERNATE MATERIALS AND METHODS

- A. Any alternate material or method not explicitly approved herein will be considered for approval on the basis of the objectives set forth in Paragraph 1.1, Purpose. Persons seeking such approval shall make application in writing to the District. Approval of any major deviation from these Standards shall be in written form. Approval of minor matters will be made in writing, if requested.
- B. Any alternate materials or methods must meet or exceed the minimum requirements set forth in these Design Standards.
- C. The written application is to include, but is not limited to, the manufacturer's specifications and testing results, design drawings, calculations and other pertinent information.
- D. Any deviations or special problems shall be reviewed on a case-by-case basis and approved by the District. When requested by the District, full design calculations shall be submitted for review with the request for approval.

1.5 CONSTRUCTION DRAWINGS

- A. Construction drawings shall conform to the requirements of these Design Standards.
- B. Detail drawings shall be included on the construction drawings for all Water System appurtenances; including valves, blowoffs, hydrants, service connections, couplings, etc.

1.6 DEFINITIONS AND TERMS

- A. In addition to other definitions contained in these Design Standards, the following definitions may apply particularly to water distribution systems. Unless otherwise defined in these Design Standards, the following definitions and abbreviations shall apply whenever used. Other definitions as outlined in the Uniform Plumbing Code (“UPC”) and the Oregon Administrative Rules (“OAR”) for the Oregon Health Authority (“OHA”) shall also apply.

- 1) Abbreviations: Acceptable abbreviations for showing types of new and existing pipe materials on the plans are as follows:
 - a) CI – Cast Iron
 - b) DI- Ductile Iron
 - c) PVC - Polyvinyl Chloride
 - d) STL- Steel
 - e) AC - Asbestos Cement
- 2) Air Gap Separation: A physical vertical separation between the free-flowing discharge end of a potable water supply and the rim of any open, non-pressurized receiving vessel.
- 3) Approved Backflow Prevention Assembly: An assembly that has been investigated and approved by OHA for preventing backflow.
- 4) Backflow: The flow of water or other fluids in a direction opposite to the normal flow. (See Back-Siphonage)
- 5) Back-Siphonage: The flowing back of used, contaminated, or polluted water from a plumbing fixture or vessel into a water supply pipe due to a negative or reduced pressure in such pipe.
- 6) Building Supply: The pipe carrying potable water from the water meter or other source of water supply to a building or other point of use or distribution on the lot. Building supply shall also mean customer line.
- 7) Cross Connection: Any connection or arrangement, physical or otherwise, between a potable water supply system and any plumbing fixture or any tank, receptacle, equipment or device, through which it may be possible for non- potable, used, unclean, polluted and contaminated water, or other substances, to enter into any part of such potable water system under any condition.
- 8) Customer Water Supply System: The water supply system of a building, premises or private system consists of all the supply pipe from the customer side of the water meter, including water service pipes, and the necessary connecting fittings, control valves, pipe and all appurtenances carrying or supplying potable water in or adjacent to the building premises served.
- 9) Distribution Mains: All mains which are not designated as transmission mains, and which are used for supply of the individual consumer. As a general rule these are the smaller mains in the water supply system.
- 10) Distribution System: Distribution main pipelines, pumping stations, valves and ancillary equipment used to transmit water from the supply source to the service line.

- 11) Double Check Valve Assembly: An assembly composed of two single, independently acting check valves, including tightly closing shut-off valves located at each end of the assembly and fitted with properly located test ports.
- 12) Double Detector Check Valve Assembly: A line-sized approved, double check valve assembly with a parallel meter and meter-sized approved, double check valve assembly. The purpose of this assembly is to provide double check valve protection for the distribution system and at the same time provide partial metering of the fire system showing any system leakage or unauthorized use of water.
- 13) Fire Hydrant Assembly: Fire hydrant, hydrant lead, mainline hydrant valve, mainline tee, and thrust restraint at the hydrant and the mainline tee.
- 14) Fire Protection Services: A connection to the public water main intended only for the extinguishment of fires and flushing necessary for its proper maintenance. All fire services connected to building sprinkler systems shall have a double detector check assembly.
- 15) Fixture Unit Equivalents: The unit flow or demand equivalent of plumbing fixtures as tabulated in the UPC.
- 16) Health Authority (“OHA”): Oregon Health Authority.
- 17) Hydrant Lead: The line connecting the fire hydrant to the District main or private fire line.
- 18) Irrigation Service: A metered connection intended for seasonal use and delivering water, which is not discharged to the sanitary sewer.
- 19) ISO: Insurance Service Office.
- 20) Mainline Hydrant Valve: The isolation valve between the District water main or private fire line and the fire hydrant.
- 21) Potable Water: Water that is satisfactory for drinking, culinary and domestic purposes and meets the requirements of the health authority having jurisdiction.
- 22) Private Distribution System: A privately owned and maintained water distribution system serving an industrial or commercial subdivision or a multi-building development on a single lot served through a master meter installed at the approved location. Private Distribution Systems must have a single entity responsible for the system. Resale of water without written approval of the District shall be prohibited.
- 23) Service Area: Shall be that area included within the legal boundaries of the Burlington Water District and such other contiguous or neighboring territory as the Board from time to time shall determine to serve.

- 24) Service Line: The waterline or pipe extending from the distribution main to the water meter, backflow prevention device, or private fire system double check valve.
- 25) Transmission Mains (Supply Lines or Water Main): Mains, which are used for transporting water from the source of supply and storage reservoirs to the centralized point of distribution and distribution reservoirs. Transmission mains may or may not supply individual consumers, but they are sized and located to transport water from centralized points of distribution to various points of interconnection with the grid system and centralized points of consumption.
- 26) Uniform Plumbing Code (“UPC”): The Uniform Plumbing Code adopted by the International Association of Plumbing and Mechanical Officials, current edition as revised by the State of Oregon, called the "Oregon State Plumbing Specialty Code."
- 27) Water Master Plan: The Water System Evaluation and Master Plan for Burlington Water District, Oregon, most recent revisions.

1.7 MATERIALS

A. General

- 1) Unless otherwise approved by the District Engineer, materials shall conform to the minimum requirements outlined herein and as shown on the Standard Details. This listing is not intended to be complete nor designed to replace the County's Public Works Construction Standards (“PWCS”).
- 2) In the case of conflicts between the provisions of these design standards and the PWCS, the more stringent as determined by the District Engineer or Superintendent shall apply. Acceptable materials shall be as outlined in these Design Standards.
- 3) It is not intended that materials listed herein are to be considered acceptable for all applications. The design engineer shall determine the materials suitable for the project to the satisfaction of the District Engineer.
- 4) All materials or products which will come in contact with or which will be used on material or products which will come in contact with potable water shall conform to the requirements of OAR 333-61-087, Product Acceptability Criteria or the National Sanitation Foundation (“NSF”) Standard 61, Drinking Water System Components - Health Effects as approved by the OHA.

B. Pipe

- 1) 4-inch Through 12-inch PVC (AWWA C-900)
 - a) PVC pressure pipe 4-inches through 12-inches in diameter shall conform to the requirements of AWWA C-900 (design stress of 4000psi), NSF approved, with

cast iron pipe equivalent (CI) outside diameter dimensions. PVC pipe shall be Class 150 pipe with wall thickness equivalent to a standard dimension ratio (SDR) of 18.

- 2) 14-inch Through 24-inch PVC (AWWA C-905)
 - a) PVC pressure pipe 12-inches through 24-inches in diameter shall conform to the requirements of AWWA-C-905 (design stress of 4000 psi), NSF approved, with cast iron pipe equivalent (CI) outside diameter dimensions. PVC pipe shall be Class 165 pipe with wall thickness equivalent to a standard dimension ratio (SDR) of 25.
- 3) Ductile Iron
 - a) Where ductile iron pipe is used for water distribution, pipe shall be Class 52 ductile iron pipe conforming to AWWA C-151, and cement-mortar lined and seal coated in accordance with AWWA C-104.
 - b) All ductile iron pipe and fittings buried underground shall be coated on the outside with a standard coating of black bituminous paint a minimum of 1 mil thick unless otherwise specified.

C. Fittings

- 1) Mechanical Joint Fittings
 - a) All MJ tees, crosses, elbows, reducers, adapters, combinations thereof, and other miscellaneous fittings 4-inches through 24-inches in diameter shall be ductile iron compact fittings in conformance with AWWA C- 153.
 - b) The minimum working pressure for all MJ cast iron or ductile iron fittings 4-inches through 24-inch in diameter shall be 350 psi.
- 2) Flanged Fittings
 - a) All flanged tees, crosses, elbows, reducers, adapters, combinations thereof, and other miscellaneous fittings 4-inches through 48-inches in diameter shall be cast iron or ductile iron fittings in conformance with AWWAC-110.
 - b) The minimum working pressure for all flanged cast iron or ductile iron fittings shall be 250 psi.

D. Couplings

- 1) Couplings shall be limited in their application to connection of new pipe work to existing waterlines, temporary installations, and where specifically approved by the District Engineer.
- 2) Couplings shall be mechanical joint solid sleeve or mechanical joint split sleeve

type couplings consisting of a ductile iron sleeve, ductile iron follower rings, rubber gaskets, and corrosion-resistant bolts and hex nuts.

- 3) Mechanical joint couplings shall have minimum pressure ratings that will accommodate maximum pressures which will be experienced during hydrostatic and leakage testing.
- 4) Solid sleeve couplings shall be Clow F-1208 or approved equivalent. Split sleeve couplings shall be Mueller H-785 or approved equivalent.
- 5) Dresser type couplings are not an approved option unless specifically approved by the County. Applications shall be limited to transitions between pipe types for which mechanical joint couplings are not available.

E. Mainline Valves

1) General

- a) All mainline valves and appurtenances shall have the name, monogram, or initials of the manufacturer cast thereon. They shall be built and equipped for the type of operation as specified herein.

2) Valve Operators

- a) All valve operators shall be totally enclosed traveling nut type manual operators, sealed and lubricated for underground service.
- b) All buried valves shall be supplied with a 2-inch square operating nut. Nuts shall have a flanged base on which shall be cast an arrow at least 2- inches long with the word "OPEN" cast on the nut to clearly indicate the direction of opening.
- c) Extension stems shall be provided for buried valves when the operating nut is four (4) feet or more below finished grade. Extension stem shall extend to within twelve (12) inches (maximum) of the finished ground surface and shall be provided with spacers which will center the stem in the valve box.

3) Valve Boxes (VB)

- a) All buried valves shall be provided with valve boxes. All valve boxes shall be provided with VC212 self-centering valve box bases as manufactured by an approved manufacturer.

4) Gate Valves (GV)

- a) For criteria regarding acceptable location for use of gate valves, see Section 1.16.
- b) All gate valves shall be resilient wedge gate valves conforming to the

requirements of AWWA C-509, except as herein modified.

- c) Gate valves shall be epoxy coated iron-body, resilient wedge non-rising stem gate valves. The wedge shall be cast iron completely encapsulated in an elastomer covering with polymer guide bearing caps on each side. The valves shall have a full diameter waterway with no grooves or recesses at the valve seat location. Flanges, where required, shall be 125 pound, full faced, drilled per ANSI B16.1.
- d) Valves shall be tested and certified by the manufacturer for shut-off at a working pressure of 200 psi and a minimum test pressure of 300 psi.
- e) Gate valves shall be Mueller A-2360, Waterous Series 500 or approved equivalent.

5) Butterfly Valves (BFV)

- a) For criteria regarding acceptable location for use of butterfly valves, see Section 1.16.
- b) All butterfly valves shall conform to AWWA C-504, except as herein modified.
- c) Butterfly valves shall be epoxy coated short body type AWWA Type-B valves. Flanges, where required, shall be 125 pound, full faced, drilled per ANSI B16.1.
- d) Valve operators shall be enclosed traveling nut type manual operators, sealed and lubricated for underground service, and shall be rated for submerged operation up to 10 psi (± 23 feet).
- e) Valves shall be tested and certified by the manufacturer for shut-off at a working pressure of 150 psi and a minimum test pressure of 300 psi.
- f) Butterfly valves shall be Pratt Groundhog series, or approved equivalent.

6) Shop Painting

- a) All valves shall be furnished with a fusion-bonded epoxy coating inside and outside conforming to the requirements of AWWA C-550.

F. Service Pipe and Fittings

- 1) For criteria regarding tapping requirements, see Section 1.19.C.
- 2) All services that are saddle tapped shall use ductile iron service saddles with stainless steel bolts and double strap clamps. All ductile iron service saddles shall be furnished with a fusion bonded epoxy coating conforming to the requirements of AWWA C-550, Romac 202S, Ford FS202 or approved equal.

- 3) Unless otherwise noted, single residential service pipe shall be 1-inch minimum diameter.
- 4) All service connections to copper pipe shall be compression fittings.
- 5) 1-inch Services
 - a) Unless otherwise specified herein, water service lines shall be seamless Type K copper pipe, conforming to AWWA C-800, 160 psi rated. All water services shall be continuous copper without splices except for services in excess of 100 feet in length.
 - b) All corporation stops shall be brass ball valve corporation stops rated to 300 psi with iron pipe thread inlet and compression outlet to adapt to copper pipe. Corporation stops shall be Ford FB-1100-4Q or approved equivalent.
 - c) Each individual water service line shall be equipped with a full-size locking ball valve meter stop assembly at the inlet to the meter. All meter stop assemblies shall be brass with copper pipe connectors as appropriate and outlet for meter coupling.
 - d) Meter stops for 3/4-inch and 1-inch meters shall be 1-inch locking angle ball valves with compression inlet. 1-inch meter stops shall be Ford BA43-444WQ, or approved equivalent. Provide all services with a 1" x 3/4" adapter on the meter stop for each 1" service.
 - e) Where permitted, service line couplings shall be compression style couplings. Couplings shall be Ford C44-44Q coupling or approved equivalent.
- 6) 1½-inch and 2-inch Services
 - a) 1½-inch water service lines shall be either seamless Type K hard copper pipe (w/out joints), conforming to AWWA C-800, 160 psi rated, or Schedule 80 PVC pipe. All fittings on PVC pipe shall be Schedule 80 PVC. Use JPS Weld-On purple primer P70 with 711 glue or approved equivalent.
 - b) 2-inch water service lines shall be Schedule 80 PVC pipe. All fittings shall be Schedule 80 PVC. Use JPS Weld-On purple primer P70 with 711 glue or approved equivalent.
 - c) 1½-inch and 2-inch water services shall be provided with high bypass coppersettlers for flanged meters, Ford VBB76-12HB-11-66 (1½") or VBB77-12HB-11-77 (2") high locking bypass or approved equivalent conforming to standard details.

1. The coppersetter shall be provided with ball valves on the inlet and outlet, with inlet valve provided with a lockwing and the outlet valve provided with a handle.
2. The bypass line shall be 1-inch diameter minimum, and shall be provided with a lockwing ball valve.
- d) 2-inch and larger services shall have a mainline tee with flanged side outlet and flanged resilient wedge gate valve conforming the requirements specified herein.
- 7) 3-inch & Larger Services
 - a) All services 3-inch and larger shall be Class 53 ductile iron pipe, with ductile iron fittings. Provide retainer glands on all MJ joints, and field- lock type gaskets on all push-on joints.
 - b) 3-inch and larger services shall have a mainline tee with flanged side outlet and flanged resilient wedge gate valve conforming to the requirements specified herein.

G. Water Meter Boxes

- 1) Unless otherwise approved by the District Superintendent or Engineer, all meter boxes must be as shown below:

WATER METER BOXES			
Service Line Size	Non-Traffic Area	Traffic Area	Inside Dimensions
3/4-inch	¹ Armorcast A6001946PCX12 Lid A6001866R	¹ Armorcast A6001946PCX12 Lid A6001866R	13"x24"
1-inch	¹ Armorcast A6001946PCX12 Lid A6001866R	¹ Armorcast A6001946PCX12 Lid A6001866R	13"x24"
1½-inch	¹ Armorcast A6001974PCXI2 LidA600J975R.	¹ Armorcast A600J 974PCXI2 LidA600J975R.	24"x36"
2-inch	¹ Armorcast A6001974PCXI2 Lid A6001975R.	¹ Armorcast A600J9 74PCX12 LidA6001975R.	24"x36"
3-inch & larger	Vault built to Public Works requirements, w/ aluminum hatch, OSHA ladder, sump pump & lockable bypass.		
¹ -or approved equivalent.			

- a) Meter boxes outside of traffic areas shall be polymer concrete boxes with non-skid polymer concrete covers and hinged reading lids.
- b) Meter boxes within traffic areas shall be polymer concrete boxes with one-piece traffic rated covers.

- c) All meter boxes shall be provided with knockouts for touch-read sensors.

H. Fire Hydrants

- 1) Unless otherwise required by the Portland Fire Department, all fire hydrants shall conform to the following:
 - a) All fire hydrants shall be improved, dry barrel, 5¼-inch compression type valve, traffic model.
 - b) Fire hydrants shall be equipped with two 2½-inch hose ports (NST), one 4½-inch pumper port (NST), 1½-inch pentagon nut, and barrel drains.
 - c) Fire hydrants shall be oriented so as to optimize access to ports, or as directed by the District Engineer.
 - d) Fire hydrants shall be Kennedy Guardian K81D (UL/FM listed), and shall be factory painted yellow.

I. Mainline Blowoffs

- 1) Blowoffs shall be sized to provide adequate flushing velocities as approved by the District Engineer.
- 2) Unless otherwise shown or authorized by the District Engineer, all blowoffs shall be provided with valve boxes and/or meter boxes.

J. Mainline Tapping Tees

- 1) Tapping tees used for making connections to existing, in-service lines shall be all stainless steel construction (including stainless steel flange) with full perimeter gasket, and shall have Class 125 outlet flanges. In all cases, the tapping tee shall be designed for use with the existing pipe materials and O.D. equivalent
- 2) All tapping valves shall be resilient wedge gate valves furnished with a fusion bonded epoxy coating inside & outside conforming to the requirements of AWWAC-550.
- 3) Any company performing mainline taps shall be prequalified with the District prior to performing any work on a project.
- 4) Contractors shall coordinate all taps with District Engineer and perform work with District staff present.

K. Underground Warning Tape

- 1) Underground warning tape shall be detectable or non-detectable acid and alkali resistant safety warning tape. The tape shall consist of a minimum 4.0 mil (0.004") thick, virgin low density polyethylene plastic film formulated for extended use

underground. The tape shall be in accordance with the APWA national color code and shall be permanently imprinted in lead free black pigments suitable for direct burial.

- 2) The tape shall be safety blue and shall be provided with the legend "CAUTION BURIED WATER LINE BELOW" or approved equivalent printed continuously down the length of the tape.

L. Toning Wire

- 1) A continuous insulated 12-gauge solid core copper toning wire shall be supplied with non-metallic pipe. Insulation shall be blue in color for potable water piping.
- 2) Additional wire shall be supplied as necessary to allow the toning wire to be looped up at all valve boxes on all lines.

M. Bore Casings and Accessories

- 1) Carrier pipe used in bore casings shall meet the minimum specifications contained herein. Casing pipe shall be of a size to permit proper construction of the carrier pipe to the required lines and grades.
- 2) Casing shall be welded smooth steel pipe conforming to the requirements of ASTM A-53 or approved equal, with a minimum yield strength of 35,000 psi.
- 3) Minimum casing size and wall thickness shall be as outlined below. Casing wall thickness shall conform to these requirements, or the requirements of the agency having jurisdiction, whichever is more stringent. Contractor shall be responsible for verifying the Bell OD or casing spacer diameter required of actual carrier pipe provided or bore grades specified, as bell diameters or casing spacer requirements may vary between manufacturers. Casing diameter shall be increased as required to allow trimming of casing spacers on grade critical bores, or where required to provide additional clearance between bells and casing.

Carrier Pipe Nominal Diameter (Inches)	Minimum Casing Pipe Diameter (Inches)	Casing Wall Minimum Thickness (Inches)
<6"	10 OD/9.5"ID	0.250 (1/4)
6" DI (CL 52, push-in joint) (Bell OD = ±8.9")	12" OD/ ±11.5" ID	0.25 (1/4)
6" PVC C900 (DR 18) (Bell OD = ±8.43")	12" OD / ±11.5" ID	0.25 (1/4)
6" PVC D3034 (DR 35) (Bell OD=±7.0")	12" OD/ ±11.5" ID (18" min. if slope ≤ 2%)	0.25 (1/4) 0.375 (3/8)
8" DI (CL 52, push-in-joint) (Bell OD = ±11.2")	14" OD /±13.37" ID	0.312 (5/16)
8" PVC C900 (DR 18) (Bell OD = ±11.06")	14" OD/ ±13.37" ID	0.312 (5/16)

Burlington Water District
Rules and Regulations
Exhibit A

Carrier Pipe Nominal Diameter (Inches)	Minimum Casing Pipe Diameter (Inches)	Casing Wall Minimum Thickness (Inches)
8" PVC D3034 (DR 35) (Bell OD= ±9.36")	14" OD I ±13.37" ID (20" min. if slope ≤ 2%)	0.312 (5/16) 0.375 (3/8)
10" DI (CL 52, push-in-joint) (Bell OD= ±13.25")	16" OD I ±15.37" ID	0.312 (5/16)
10" PVC C900 (DR 18) (Bell OD= ±13.57")	16" OD /±15.37" ID	0.312 (5/16)
10" PVC D3034 (DR 35) (Bell OD= ±11.7")	16" OD /±15.37" ID (24" min. if slope ≤ 2%)	0.312 (5/16) 0.50 (1/2)
12" DI (CL 52, push-in joint) (Bell OD= ±15.37")	18" OD /±17.25" ID	0.375 (3/8)
12" PVC C900 (DR 18) (Bell OD =±16.13")	18" OD /±17.25" ID	0.375 (3/8)
12" PVC D3034 (DR 35) (Bell OD =±13.94")	18" OD /±17.25" ID (24" min. if slope ≤ 2%)	0.375 (3/8) 0.50 (1/2)
14" DI (CL 52, push-in joint) (Bell OD = ±17.85")	22" OD I ±21" ID	0.50 (1/2)
14" PVC C900 (DR 25) (Bell OD= ±17.94")	22" OD I ±21" ID	0.50 (1/2)
15" PVC D3034 (DR 35) (Bell OD= ±17.05")	22" OD I ±21.2" ID (24" min. if slope ≤2%)	0.50 (1/2) 0.50 (1/2)
16" DI (CL 52, push-in joint) (Bell OD = ±20")	24" OD I ±23" ID	0.50 (1/2)
16" PVC C905 (DR 25) (Bell OD =±20.41")	24" OD I ±23" ID	0.50 (1/2)
18" DI (CL 52, push-in joint) (Bell OD = ±22.2")	26" OD I ±25" ID	0.50 (1/2) 0.50 (1/2)
18" PVC C905 (DR25) (Bell OD = ±22.87")	26" OD I ±25" ID	0.50 (1/2) 0.50 (1/2)
18" PVC F679 (PS46) (Bell OD= ±20.85")	24" OD I ±23" ID (28" min. if slope ≤2%)	0.50 (1/2)
20" DI (CL 52, push-in joint) (Bell OD = ±24.3")	28" OD / 27" ID	0.50 (1/2)
20" PVC C905 (DR25) (Bell OD =±25.34")	28" OD/ 27" ID	0.50 (1/2)
21" PVC F679 (PS46) (Bell OD = ±24.58")	28" OD/ 27" ID (30" min. if slope ≤ 2%)	0.50 (1/2)
24" DI (CL 52, push-in joint) (Bell OD = ±28.5")	32" OD I ±31" ID	0.50 (1/2)
24" PVC C905 (DR25) (Bell OD= ±30.27")	34" OD/ 33" ID	0.50 (1/2)
24" PVC F679 (PS46) (Bell OD =±27.65")	32" OD I 31" ID (34" min. if slope ≤ 2%)	0.50 (1/2)
27" PVC F679 (PS46) (Bell OD = ±31.16")	36" OD I ±34.75 ID	0.625 (5/8)
30" DI (CL 52, push-in joint) (Bell OD = ±34.95")	38" OD I ±36.75" ID	0.625 (5/8)
30" PVC C905 (DR 25) (Bell OD =±37.12")	42" OD /±40.75" ID	0.625 (5/8)

Carrier Pipe Nominal Diameter (Inches)	Minimum Casing Pipe Diameter (Inches)	Casing Wall Minimum Thickness (Inches)
30" PVC F679 (PS46) (Bell OD = ±35.61")	42" OD I ±40.75" ID (44" min. if slope ≤ 2%)	0.625 (5/8)
36" DI (CL 52, push-in joint) (Bell OD = ±41.4")	46" OD I ±44.75" ID	0.625 (5/8)
36" PVC C905 (DR25) (Bell OD = ±44.43")	48" OD I ±46.75" ID	0.625 (5/8)
36" PVC F679 (PS46)	48" OD I ±46.15" ID	0.625 (5/8)
42" PVC F679 (PS46) (Bell OD = ±49.61")	54" OD I ±52.75" ID (56" min. if slope ≤ 2%)	0.75 (3/4)
48" DI (CL 52, push-in joint)	60" OD I ±58.5" ID	0.75 (3/4)
48" PVC F679 (PS46) (Bell OD = ±56.62")	60" OD I ±58.5" ID (64" min. if slope ≤ 2%)	0.75 (3/4)
Casing diameter shall be increased as required to allow trimming of casing spacers on grade critical bores.		

- 4) The class of casing specified is based upon assumed superimposed loads and not upon the stresses resulting from jacking or boring operations. Any increase in casing strength to withstand jacking or boring operations shall be the responsibility of the Contractor.
- 5) Casing Spacers (Skids)
 - a) Casing spacers shall be Model SSI-8 for carrier pipes up to 18-inch diameter and Model SSI-12-2 for larger pipe sizes as manufactured by an approved manufacturer.
 - b) Casing spacers shall be bolt-on style with a shell made of at least two halves. The band material shall be manufactured of a minimum 14-gauge T-304 stainless steel. The runners shall be at least 7 inches long for SSI-8 models and 11 inches long for SSI-12 models, and manufactured of high abrasion resistant and low co-efficient of friction, glass filled polymer.
 - c) The spacer shall have a flexible EPDM liner having a minimum thickness of 0.090 inches, with a hardness of durometer "A" 85-90. The liner shall have a rating of no less than 60,000 VPM and water absorption of 1% maximum. All welds are to be chemically passivated and all hardware to be stainless steel.
 - d) All spacers used for grade critical gravity sewer and storm lines shall have field replaceable runners to allow for grade and elevation adjustment.
 - e) A minimum of three (3) casing spacers per length of pipe shall be required, or 6-foot on center maximum spacing, whichever is greater.
- 6) End Seals
 - a) Where casings are filled with sand (gravity or non-pressure pipelines), end seals shall be grout/masonry end caps with 4" minimum diameter sand feed

and vent tubes at each end. The vent tubes shall be plugged with grout after the casing is filled with sand.

- b) Where casings are not filled with sand (pressure pipelines), end seals shall be Model AC (pull-on) or Model AW (wrap-around with pressure sensitive butyl mastic strips) end seals as manufactured by APS, or approved equivalent, fastened to the casing and carrier pipe with stainless steel bands.

1.8 GENERAL DESIGN CONSIDERATIONS

- A. The water system shall have sufficient capacity for the District to maintain 40 psi at the building entrance for one and two family dwellings. For other development, the system shall have sufficient capacity for the District to provide minimum pressure of 35 psi at the building side of the meter during periods of maximum use, and to provide sufficient volumes of water at adequate pressures to satisfy the maximum expected daily consumption plus fire flows.
- B. Normal working pressure in the distribution system should be approximately 70 psi with a range of 40 psi to 100 psi.
- C. Head loss shall be determined by the Hazen-Williams equation based on the following coefficients:

Hazen-Williams Coefficients	
Pipe Diameter	C Value
8 Inches and Less	100
10 to 12 Inches	110
Greater than 12 Inches	120

- D. Velocities in mains shall normally range from three (3) to six (6) feet per second for average demand to a maximum velocity of ten (10) feet per second for maximum day demand plus fire flow.
- E. A 20-psi residual pressure under fire flow conditions shall be maintained at all points in the distribution system. Generally, a maximum velocity of ten (10) feet per second will govern for sizing mains at all other locations of the service level where this criteria does not govern.
- F. Private Distribution Systems shall limit velocities as required by the Oregon State Plumbing Specialty Code, Installation Standards.
- G. Providing for Future Development
 - 1) As a condition of water service, all developments will be required to provide public water mains of sufficient size for fire protection to adjacent parcels, as well as

connection (to the new system) of existing water lines, hydrants or services crossed or intercepted by or adjacent to the new waterlines, at locations as required by the District Engineer (see also, Design Standards section 1.15). This shall include the extension of water mains in easements across the property to adjoining properties and across the street frontage of the property to adjoining properties when the main is located in the street right-of-way. This shall include extension to the far side of streets fronting or adjacent to the development as required to avoid work within or under these streets in the future. This shall include waterlines that are oversized to provide capacity for required fire flows.

- 2) In general, water distribution systems should be designed for maximum development of the Service Area with recognition of possible urban renewal, industrial expansion, etc.

1.9 WATER SYSTEM CAPACITY

A. General

- 1) In areas not addressed in the Water Master Plan, design capacities shall be determined by consideration of the following factors and assumptions:
 - a) Area to be serviced, both immediate and adjacent.
 - b) Current and projected population within the areas to be served.
 - c) Current and projected land use within the areas to be served.
 - d) Commercial, industrial, or institutional users to be served.
 - e) Changes in any of the above factors that are likely to occur within a foreseeable time period.
- 2) In the absence of consumption data or other reliable information, the following factors may be assumed:
 - a) Peak hour demands as follows:
 - (1) 5 gpm per single family residential
 - (2) 2.5 gpm per dwelling unit for multiple family residential
 - (3) 5,000 gal/ac/day for commercial development
 - (4) 10,000 gal/ac/day for industrial development
 - b) Demand for unique commercial installations, industrial users, the District's, multiple and institutional developments shall be calculated on an individual basis.

B. Fire Flow Requirements

- 1) Unless otherwise approved or required by the District Engineer and the local Fire Marshall, minimum fire flows shall be as follows:

MINIMUM FIRE FLOW REQUIREMENTS**		
Location	Recommended Fire Flow(gpm)	Duration (hours)
Residential R-1	1,000	2
	1,250	2
Residential Commercial RC	2,500	3
Public (Schools & Institutions)	2,500	3
Commercial/Industrial (C-1, C-2, I) New Facilities	3,250	3
	up to 4,000	4
** Higher values may be required based on Fire Marshall or ISO requirements. ** These values do not supersede or take the place of IFC or IBC fire flow requirements. Higher values may be necessary based on Fire Code, Fire Marshall or ISO requirements. Reductions may be allowed by the Fire Chief for buildings with fire sprinkler systems.		

- 2) In all cases, all new fire hydrants shall be capable of delivering a minimum of 1,000 gpm at 20psi residual system pressure. This requirement will apply independently to each phase of multi-phase projects.

1.10 LOOPING

- A. The distribution system mains shall be looped at all possible locations.
- B. All water lines shall be looped and valved so that the removal of any single line segment from service will not result in more than one fire hydrant being taken out of service.
- C. The installation of permanent dead-end mains upon which fire protection depends and areas of large demands on single mains will not be permitted.

1.11 BLOWOFFS

- A. All dead-end mains shall terminate with a blowoff assembly or a fire hydrant.
- B. Permanent dead-ends shall have a permanent blow-off assembly and a permanent thrust restraint system. Permanent blowoffs in cul-de-sacs shall be located in front of the curb within five (5) feet from the curb face.
- C. Mains which can conceivably be extended at some later date shall have a mainline valve (same size as mainline) in front of the blowoff assembly, and a thrust restraint system which allows the mainline valve to be connected without taking the line out of service.

- D. Blowoffs shall be sized to ensure that the water mains can be flushed at a minimum velocity of 2½ feet per second in accordance with AWWA C-650. The following table may be used as a minimum guideline assuming 40 psi minimum residual system pressure under flushing conditions.

MAINLINE BLOWOFF SIZES	
Water Main Diameter	Minimum Blowoff Diameter
6 and 8-inch	2-inch
10 and 12-inch	4-inch
>12	As required

- E. The design engineer shall submit calculations showing that these flushing velocities can be satisfied.
- F. Temporary blowoffs larger than 2-inches in diameter shall have a valve conforming to the requirements contained herein for mainline valves.
- G. Temporary blowoffs, where required for cleaning new water mains, shall be located at the lower end of the line to be flushed whenever possible.

1.12 MINIMUM DEPTH

- A. The standard minimum cover over buried water mains within the street right-of-way or easements shall be thirty-six (36) inches from the finished grade, except that a minimum of 40 inches cover shall be required for waterlines in fill slopes.
- B. Finish grade shall normally be determined as follows:

FINISH GRADE	
Mainline Location	Finish Grade
Waterline under sidewalk in right-of-way	Top of curb
Waterline in front of curb	Gutter
Waterline in cut slope behind sidewalk	Top of curb
Fill slopes	Perpendicular from pipe to surface
Easement	Finish grade at pipe centerline

- C. Where the waterline is located in the cut side slope, in an undeveloped right-of-way, or along a roadway developed at less than ultimate width (including sidewalks), the waterline shall be placed at a depth sufficient to ensure that 36-inches of cover is maintained at the time of final construction of the roadway.

1.13 MINIMUM MAINLINE SIZE

Minimum sizes for water mains shall be as follows:

MAINLINE SIZE REQUIREMENTS	
Minimum Diameter	Type of Mainline
6-inch	Public lines in cul-de-sacs, which cannot be looped in the future and which are beyond the fire hydrant envelope of 250 feet to the furthest point on any existing or future structure. Private fire line supplying either a single fire hydrant or a building fire suppression system. Looping of private fire lines that supply hydrants will be required.
8-inch	Minimum size water main for the public water system. Looping back into the distribution grid shall be at intervals as required by the District, but shall generally not exceed ±600 feet.
8-inch	Public water distribution mains, and permanently dead-end mains supplying fire hydrants with a required fire flow of 1,500 gpm or less.
10-inch & Larger	As required for transmission mains, distribution mains in industrial subdivisions, and fire lines supplying more than 1,500 gpm.

1.14 ALIGNMENT AND LOCATION

A. General

- 1) Water lines shall generally be parallel to the right-of-way or easement wherein they lie.
- 2) Unless otherwise required by the District Engineer, water lines shall generally be located on the south and west sides of the right-of-way wherein they lie.

B. Location in Relation to Sanitary Sewer Lines and Other Utilities

- 1) Water mainlines shall be separated from all other utilities by a minimum of 5 feet.
- 2) Water mainlines shall generally be separated from sewer mainlines by a minimum of 10 feet. In no case shall the separation be less than 5 feet or as required by OAR 333.
- 3) Sanitary Sewer Main Crossings
 - a) Where a water mainline crosses below or within 18-inches vertical separation above a sanitary sewer main or lateral, one full length of AWWA C-900 PVC pipe (DR 18) shall be centered at point of crossing.

C. Location in Right-of-Ways

- 1) Unless otherwise approved by the District Engineer, water mainlines shall generally

be located in the street right-of-way between the curb and the right-of-way line, centered under the sidewalk.

- 2) The distance between the mainline and the curb shall vary as little as possible. On curved streets, mains may be laid on a curve concentric with the street centerline with deflections no greater than the manufacturer's specifications, or mains may be laid in straight lines along the tangent between selected angle points to avoid conflicts with other utilities. The angle point and tangent section shall not be closer than 5 feet from the right-of-way line, nor more than 3 feet in front of the curb face.

D. Location in Easements

- 1) Unless otherwise specified or authorized by the District, minimum easement widths for water mainlines shall be fifteen (15) feet for normal depth lines.
- 2) Mainlines in easements will be allowed only in cases where it is required in order to loop a mainline to avoid a permanent dead-end condition, and only after all reasonable attempts to loop the mainlines in a right-of-way have been exhausted.
- 3) When water mainlines in easements are approved by the District, the easement shall be centered on the mainline, and the mainline shall be offset a minimum of 6 feet from any property line.
- 4) The conditions of the easement shall be such that the easement shall not be used for any purpose, which would interfere with the unrestricted use for water mainline purposes. Under no circumstances shall a building or structure, trees, ornamental landscaping or fence be placed over a water mainline or easement. Prohibited structures shall include footings, decks and overhanging portions of structures located outside the easement.
- 5) Easement locations for public water mainlines serving the District, apartment complexes or commercial/industrial development in the District, shall be in parking lots, private drives or similar open areas, which will permit unobstructed vehicle access for maintenance by District employees.
- 6) Water mainlines with inside diameters larger than 12-inches will require wider easements.
- 7) Common placement in the easement of water and sewer or storm drain line may be allowed under certain conditions subject to approval by the District Engineer. Easements wider than the minimum will be required.
- 8) Common easements will be reviewed on a case-by-case basis. Separation of utilities must meet OHA requirements.
- 9) All easements must be furnished to the District for review and approval prior to recording.

E. Phased Construction

- 1) Water mains installed by phased construction, which will be extended in the future, shall terminate with a mainline valve, blow off and permanent thrust restraint system.
- 2) All developments will be required to extend mains across existing or proposed streets for future extensions by the District or other developments. All terminations shall be planned and located such that new or existing pavement will not have to be cut in the future when the main is extended.
- 3) The construction plans for each phase shall be capable of standing alone, including provisions for looping and minimum fire flows.

F. Location in Relation to Ditches and Drainage Channels

- 1) Surface water crossings of mains shall be in accordance with OAR 333 and the requirements outlined herein.
- 2) Mains crossing ditches or drainage channels shall be designed to cross as nearly perpendicular to the channel as possible.
- 3) The following surface water crossings will be treated on a case-by-case basis:
 - a) Ditch or drainage channel crossing for pipes of 12-inch diameter and greater.
 - b) River or creek crossings requiring special approval from the Oregon Department of State Lands.
- 4) The minimum cover from the bottom of the ditch or drainage channel to the top of pipe shall be a minimum of thirty-six (36) inches unless otherwise approved by the District Engineer and the OHA.
- 5) A scour pad centered on the water line will be required for mains where the potential for erosion exists as determined by the District Engineer. The District Engineer will review the size and design of scour pads on a case-by-case basis.

1.15 VALVES

A. Sizes

- 1) In general, valves shall be the same size as the mains in which they are installed. Reducers for reconnection into existing water mains less than 8-inches in diameter shall be placed between the new valve and the existing line.
- 2) Unless otherwise approved or required by the District Engineer, valves shall conform to the following table.

Required Valves by Size and Operating Conditions		
Valve Size	Static Pressure	Valve Style
10-inch and smaller	< 120 psi	Gate Valve
8-inch & 10-inch	120 psi	Butterfly Valve
12-inch & larger	All pressures	Butterfly Valve

- 3) Valve types and materials shall conform to the requirements of these Design Standards.

B. Location

- 1) Distribution system valves shall be located at the tee or cross fitting as nearly as possible.
- 2) There shall be a sufficient number of valves so located that not more than four (4) and preferable three (3) valves must be operated to effect any one particular shutdown. The spacing of valves shall be such that the length of any one shutdown in high value areas shall not exceed 500 feet nor 800 feet in other areas.
- 3) A tee-intersection shall be valved on two branches and a cross-intersection shall be valved on three branches.
- 4) Hazardous crossings (ie. creek, railroad, freeway crossings, etc.) shall be valved on each side of the crossing.
- 5) Distribution branches on transmission mains shall be spaced not more than 800 feet apart where practical and shall be valved and plugged.
- 6) Transmission water mains shall have valves at spacings as required by the District Engineer.

C. Tapping Tees

- 1) Tapping tees to make connection to existing, in-service lines are only allowed in cases where the District determines that water service cannot be interrupted to cut in a tee or cross, and where the additional in-line valve required is not needed for system isolation as outlined above.

1.17 FIRE HYDRANTS

A. Coverage

- 1) Preferred coverage shall result in maximum hydrant spacing of 500 feet in residential areas, 300 feet in high-value areas, including industrial subdivisions and no further than 250 feet from the furthest point of any dwelling, business, garage or building. Hydrant stubs with mainline valves will be required as a minimum in undeveloped areas.

B. Location

- 1) No fire hydrant shall be installed on a main of less than 8-inch diameter unless it is in a looped system of 6-inch mains. The hydrant lead shall be a minimum of 6-inches in diameter.
- 2) Hydrants shall be placed in locations approved by the local Fire Marshall.
- 3) In general, hydrants shall be located at corner of street intersections where possible. Hydrants located at points other than intersections shall be located at the extension of property lines.
- 4) Unless otherwise approved by the District, hydrants shall be placed between the sidewalk and the property line.
- 5) No hydrant shall be installed within five (5) feet of an existing utility pole or guy wire nor shall a utility or guy wire be placed within five (5) feet of an existing hydrant.

C. Hydrant Valves

- 1) Each fire hydrant shall have a hydrant valve and valve box at the mainline hydrant tee which will permit removal and repair of the hydrant without shutting down the water main supplying the hydrant.
- 2) Hydrant valves shall be resilient wedge gate valves.
- 3) The hydrant valve shall be connected directly to the mainline tee using a flange joint.
- 4) If the length of the hydrant lead is greater than 30 feet, an additional gate valve shall be provided within 3 feet of the hydrant.

D. Hydrant Leads

- 1) All hydrant leads shall be Class 52 ductile iron, 6" minimum diameter, with retainer glands at both ends.
- 2) All hydrant leads shall consist of a single piece of pipe without joints. Any joints allowed on hydrant leads shall be provided with fully restrained gaskets (Field-Lok or equivalent). Exceptions, for long hydrant leads, must be approved in writing by BWD & the local Fire Marshall.

E. Hydrant Bury & Exposure

- 1) Hydrant bury shall not be sufficient to provide a minimum of 36-inches of cover over the hydrant lead. In no case shall the bury be less than the depth of the waterline from which the hydrant is served.
- 2) The hydrant shall be set such that the base of bottom flange bolts are a minimum of

2-inches and a maximum of 6-inches above finish grade following all landscaping and surface restoration.

1.17 AIR RELEASE VALVES

A. General

- 1) Provisions for air relief shall be provided at all high points of waterlines. Where possible, location of service taps at high points in the line is preferable to the installation of an air relief valve.
- 2) Where service taps cannot be used, an air release valve shall be permanently installed at high points on all water mains at all location where air can accumulate. An automatic air release valve shall be installed in a manhole off of the street where flooding of the manhole or chamber will not occur.

B. Air Release Valve Piping

- 1) The open end of an air release pipe from automatic valves shall extend to the top of the manhole at least twelve inches above grade and provided with a screened, downward facing elbow. Grade shall mean the existing ground elevation adjoining the manhole. An opening twice the size of the vent pipe shall exist at grade to prevent flooding of the vault.

1.18 SERVICE LINES

A. General

- 1) The use of pumps on a service line to provide adequate pressure to a subdivision lot or property located above the pressure level of the supply main shall be prohibited.
- 2) Each legal lot of record shall be connected by a separate water service line connected to the public or approved private water main. Combined water service lines will be permitted only when the property cannot legally be further divided. An example of this is a residential lot with a house and unattached garage or shop with plumbing fixtures.
- 3) Separate water services and separate meters shall be installed to serve each side of duplex lots. Separate water services and separate meters shall be installed to serve each unit of condominiums.
- 4) Additional water service lines must be stubbed into the property lines sufficient to serve all residential parcels, which can be further partitioned in the future where such future partition would require that the streets be cut to install such services.

B. Sizes

- 1) Standard service line sizes are 1-inch, 1½-inch, 2-inch, 3-inch, 4-inch, 6-inch and 8-

inch. Service lines will be reviewed for effects on the distribution system and shall not be greater in size than the distribution main.

MINIMUM SERVICE SIZE	
Type of Service	Minimum Service Size
Single residential service	1-inch
Commercial Service	1" minimum
Note: The next larger service size may be required for residential lots large enough to be partitioned into additional lots without a water main extension	

- 2) The water service line on the private side of the meter may not be larger than one nominal pipe size larger than the service line size.
- 3) Commercial services shall not be smaller than 1 inch. For new streets or streets being cut for service installation, far side commercial services shall be installed in a 4-inch minimum size PVC sleeve.
- 4) Service piping shall be equal to or greater than the meter size.
- 5) For 3-inch and larger services, design drawings must be submitted showing the vault and fitting requirements, including a lockable bypass line, with the expected flow requirements and proposed usage.

C. Tapping requirements

Tapping requirements for water service lines shall be as outlined below.

WATER SERVICE TAPPING REQUIREMENTS		
Service Size	Mainline Type	Tapping Requirements
1"	All pipe types	Service Saddle
1½"	All pipe types	Service Saddle
2" & larger	All pipe types	Mainline tee with flanged valve

D. Location

- 1) Domestic
 - a) The service lines shall normally extend from the main to a point 6-inches behind the back of the sidewalk. A curb stop and meter box shall be located at the termination of the service line.
 - b) The meter stop shall be located such that the front of the meter box is 3-inches behind the sidewalk.
 - c) In general, individual service connections shall terminate in front of the

property to be served. Double services shall be located on each side of a common side property line.

- d) Domestic service lines shall not be connected to fire protection services, including hydrant leads.
- 2) Fire Service
- a) A backflow prevention assembly shall be placed on fire service lines as required by the District.
 - b) Plans for fire service lines shall meet the requirements as outlined in these Design Standards and shall be stamped by a licensed Civil Engineer.
 - c) Drawings for fire services shall include vicinity map, adjoining street name, width, curb and property line, location of existing water line referenced to the property line, existing hydrant locations and the distance to property pins where the service crosses the property line.

1.19 WATER METERS

A. General

All water meters within the Service Area of the District will be furnished and installed by the District at the request and expense of the customer. The developer must install the service line, meter box and all piping within the meter box.

B. Location

- 1) General
 - a) Meters shall be located at the termination of the District service line.
 - b) A public utility and access easement shall be provided to and around any meter boxes set on private property. The easement shall be sized to provide a minimum of five (5) foot clearance around the meter box or vault on all sides.
- 2) 3/4-inch through 2-inch Meters
 - a) In the right-of-way in a location that allows for easy reading and maintenance, preferably 3-inches behind the back of sidewalk.
- 3) 3 Inch and Larger Meter
 - a) On private property adjacent to the public right-of-way to allow reading and maintenance. It must be accessible with a crane truck to within ten feet of the installation with a ten-foot vertical clearance.
 - b) The meter, vault and piping are to be protected from freezing, vandals and vehicles. The area around the vault must be sloped in such a manner to prevent

storm water from ponding over or running into the vault.

- c) A minimum three-foot clear space must be provided around the vault to provide ample working space for maintenance.
- d) All 3-inch and larger meters shall be provided with a remote readout head located such that it can be read without entering the meter vault.
- e) A sump pump shall be installed and maintained in the meter vault (of all meters larger than 2-inch) by the property owner, discharging to a storm drain or other location approved by the District. Owner shall be responsible for all permits & costs associated with providing power to the meter vault for the sump pump.
- f) The meter, with approval by the District, may be located in the same vault with a backflow prevention device, provided a completed dimensioned design is submitted with a request for variance.

C. Meter Boxes

- 1) The developer for each water service and meter location shall provide meter boxes. Double set meters (2 meters in 1 box) are not allowed.
- 2) Meter boxes shall be set level to finish grade. The developer or builder shall be responsible for setting meter boxes and services to finish grade prior to installation of water meters by the District.
- 3) Meter boxes that do not provide all required clearances and spacing, so as to allow the District to install a standard meter without removing the box, will be required to be reset or replaced by the developer or builder (at their sole expense), prior to installation of the meter by the District.

1.20 PRIVATE DISTRIBUTION SYSTEMS

- A. General design considerations for Private Distribution Systems shall conform to requirements set forth by the OHA, by the Oregon State Plumbing Specialty Code (Chapter 10).
- B. All District transmission mains and distribution mains within private developments (if any) shall be in a public right-of-way or exclusive easements to Burlington Water District and shall conform to these Design Standards. Each connection of a Private Distribution System to the District's system shall be through an approved backflow prevention assembly and meter.
- C. Requirements for capacity, materials, looping, valves, fire protection, service lines and meters shall also be applicable to design within the District's Service Area including any area at the time it comes or begins the process to come into the District's Service Area.
- D. The resale of water without written approval of the District shall be prohibited. Written authorization from the District shall be required for each service connection and for any

sale of water.

1.21 BACKFLOW PREVENTION

A. General

- 1) All backflow devices shall be testable and include provisions for testing by a certified backflow testing person or organization.
- 2) An approved backflow prevention assembly with an approved metering system shall be required for each use in the following instances:
 - a) When a private line must be extended from or looped between two (2) or more District mains in order to obtain the required flow and the resultant loop is no benefit to the District grid system.
 - b) When pipe materials other than those approved for potable water are installed on private fire services.
 - c) On all private water lines or distribution system attached to the District's distribution system.
 - d) On all private water lines or distribution systems attached to the District grid system at the master meter on the detector check assembly.
 - e) On any premise having a cross connection, as that word is defined in the Oregon Administrative Rules for the Oregon Health Authority.
 - f) When an auxiliary water supply exists on the property being served. As determined by the District Engineer and OHA requirements.
- 3) An approved reduced pressure backflow prevention assembly with an approved metering system shall be required for service connections in high hazard areas as determined by the District Engineer.
- 4) The backflow assemblies must meet the District approved assembly standards, which standards are taken from the current approved list of assemblies maintained by the OHA.

B. Location

- 1) The approved backflow prevention assembly shall be installed on the property being served in a place accessible for District inspecting/testing and located as follows:
 - a) Before any branch, immediately downstream of the meter; or
 - b) If not at meter, at the property line; or
 - c) If in the building, before the first branch or hazard being controlled or as determined by the District Superintendent; or

- 2) If installed outside the building being served, it shall be placed at the property line or easement line, in a vault or structure in accordance with the manufacturer's recommendations and as approved by the District Engineer or Superintendent. Vaults must have a sump and be watertight.
- 3) The distance from a fire hydrant to the fire department connection shall not exceed 40 feet unless otherwise approved in writing by the Fire Chief, but in no case shall a distance of greater than 60 feet be allowed.

1.22 UNDERGROUND WARNING TAPE

- A. Detectable or non-detectable acid and alkali resistant safety warning tape shall be provided along all mainlines not located under sidewalks or paved portions of public streets.
- B. Underground warning tape shall be placed a minimum of 12-inches and a maximum of 18-inches below the finish ground surface, and shall be continuous the entire length of the mainline as specified.

1.23 MAINLINE BORE CROSSINGS

- A. Casing size shall adequate to permit proper construction of the carrier pipe to the required lines and grades. Carrier pipe used in bore casings shall be as specified herein.
- B. All bore crossings shall be provided with casing spacers and end seals. Casing spacer configuration shall conform to the manufacturer's recommendations, but in no case shall less than 3 spacers per length of pipe be used.
- C. In order to prevent over-belling of PVC or other flexible pipe while installing it through the casing, provide a method for restricting movement between the assembled bell and spigot conforming with the manufacturer's recommendations.
- D. The design of the bore crossing shall include the following as a minimum:
 - 1) Casing and carrier pipe materials and dimensions, including outside bell diameters of the carrier pipe.
 - 2) Details for any part of the system which must be changed as a result of the boring operation (manhole, headwall, etc.).